CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7770-2252:0501

CATEGORY: 7770 -- VALVES/SWITCHES

LISTEE: Jinan Meide Casting Co., Ltd.Meide Science & Technology Park, Pingyin Industrial Park, Jinan Shandong Province, 250400 China
Contact: Lei Zhan 8653187856308 Fax 8653187879387
Email: lei.zhan@meide-casting.com

DESIGN: Model ZSJZYS Vane-type Waterflow Alarm Indicator, in sizes 2", 2.5", 3", 4", 5", 6", and 8", with a pneumatically controlled mechanical delay mechanism (adjustable 0-90 seconds delay time). Must be located in an environment between 32°F to 120°F.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 125/250VAC 5A, 24/30VDC 3A
Working Pressure: 363 PSI

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and FM label.

APPROVAL: Listed as waterflow alarm indicator for use with fire sprinkler systems. Refer to listee's Installation Instruction Manual for details.

5-4-21 VWW

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **May 07, 2021** *Listing Expires* **June 30, 2021**

Authorized By: *DAVID CASTILLO,, M.E., F.P.E.*
Fire Engineering Division